

**Sub-Divisional
Water Testing, Laboratory
DWS Sub-Division Teliamura
Khowai, Tripura.**

***WATER TESTING REPORT:-**

| Sl. No. | Name of School | Source of Sample | Type of Sample | Date of Test | Result (mg/l) | | | | | Remarks | |
|---------|------------------------------|------------------|----------------|--------------|---------------|-----------------|-------------|---------|-----------|---------|---|
| | | | | | PH | Turbidity (NTU) | Iron (mg/l) | Calcium | Magnesium | | Hardness |
| 1 | Maiganga Sukanta H.S. School | SBDTW | Clear Water | 09-09-21 | 6.6 | 0.0 | 0.13 | 24 | 13 | 110 | P. Limit PH:-6.6-8.5 Turbidity:-05, IRON:-1.0 mg/l. Calcium- 75-200 mg/l. Magnesium-30-150 mg/l. Hardness-200-600 mg/l. |

(Signature)
Jr. Research Assistant,
DWS Sub-Division Teliamura
Khowai Tripura.

(Signature)
Assistant Engineer
DWS Sub-Division Teliamura
Khowai Tripura.